



Product Service

CERTIFICATE

No. Z2 118905 0001 Rev. 00

Holder of Certificate: **Sunrover Power Co., Ltd.**
No.800 Wangjiang West Road, High-tech Zone
230088 Hefei City, Anhui Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262221601-00

Valid until: 2027-09-26

Date, 2022-11-28

(Zhulin Zhang)

CERTIFICATE

No. Z2 118905 0001 Rev. 00

Model(s):

SUNxxx-DE21M(20) (xxx=640-670 in steps of 5)
 SUNxxx-DE21M(19) (xxx=585-605 in steps of 5)
 SUNxxx-DE21M(18) (xxx=540-560 in steps of 5)
 SUNxxx-DE21M(17) (xxx=525-545 in steps of 5)
 SUNxxx-DE21M(16) (xxx=495-505 in steps of 5)
 SUNxxx-DE21M(15) (xxx=470-485 in steps of 5)
 SUNxxx-DE21M(14) (xxx=445-455 in steps of 5)
 SUNxxx-DE21M(13) (xxx=410-430 in steps of 5)
 SUNxxx-DE21M(12) (xxx=395-405 in steps of 5)
 SUNxxx-DE21M(11) (xxx=485-515 in steps of 5)
 SUNxxx-DE21M(10) (xxx=385-410 in steps of 5)
 SUNxxx-DE21M(09) (xxx=290-310 in steps of 5)
 SUNxxx-DE21M(08) (xxx=190-205 in steps of 5)
 SUNxxx-DE21M(07) (xxx=95-100 in steps of 5)
 SUNxxx-DE17S(15) (xxx=445-465 in steps of 5)
 SUNxxx-DE17S(14) (xxx=405-425 in steps of 5)
 SUNxxx-DE17S(13) (xxx=370-385 in steps of 5)
 SUNxxx-DE17S(12) (xxx=330-345 in steps of 5)
 SUNxxx-DE17S(11) (xxx=295-310 in steps of 5)
 SUNxxx-DE17S(10) (xxx=220-230 in steps of 5)
 SUNxxx-DE17S(09) (xxx=185-190 in steps of 5)
 SUNxxx-DE17S(08) (xxx=145-155 in steps of 5)
 SUNxxx-DE17S(07) (xxx=110-115 in steps of 5)
 SUNxxx-DE16S(14) (xxx=375-425 in steps of 5)
 SUNxxx-DE16S(13) (xxx=340-390 in steps of 5)
 SUNxxx-DE16S(12) (xxx=310-350 in steps of 5)
 SUNxxx-DE16S(11) (xxx=280-315 in steps of 5)
 SUNxxx-DE16S(10) (xxx=250-280 in steps of 5)
 SUNxxx-DE16S(09) (xxx=185-210 in steps of 5)
 SUNxxx-DE16S(08) (xxx=155-175 in steps of 5)
 SUNxxx-DE16S(07) (xxx=125-140 in steps of 5)
 SUNxxx-DE16S(06) (xxx=90-105 in steps of 5)
 xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.



CERTIFICATE

No. Z2 118905 0001 Rev. 00

**Tested
according to:**

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
EN 61215-1:2016
EN 61215-1-1:2016
EN 61215-2:2017
EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06